

Proof of intrinsic safety

For intrinsically safe circuits with a supply.

device:

myDatalogEASY IoT ATEX

associated equipment:

Manufacturer	Type	Device	EU type examination certificate	ATEX marking
Microtronics	Zenerbarriere 167	myDatalogEasyIoT ATEX	SIQ 22 ATEX 184 X SIQ 22 ATEX 185 U	<Ex> II 3(1)G Ex ec nC [ia Ga] IIC T4 Gc <Ex> II 3(1)G Ex ec [ia Ga] IIC Gc

max. output voltage	Uo [V]=	26,25
max. output current	Io [A]=	0,084
max. output power	Po [W]=	0,549
max. external capacity	Co [nF]=	48,5
max. external inductance	Lo [μH]=	2530

intrinsically safe equipment:

Manufacturer	Type	Device	EU type examination certificate	ATEX marking
Alicat Scientific	Alicat IS-Max/Pro	Pressure and Flow Monitor	DEKRA 22ATEX0075X	<Ex> II 1G Ex ia IIC T4 Ga

max. input voltage	Ui [V]=	28
max. input current	Ii [A]=	0,093
max. input power	Pi [W]=	0,651
max. internal capacity	Ci [nF]=	0
max. internal inductance	Li [μH]=	0

cable + pressure compensation element:

Manufacturer	Type	length [m]
Alicat	Pre-fabricated moulded cable	
		88

cable capacitance [nF/m]	0,55
cable inductance [μH/m]:	1

resulting cable capacitance	Cc [nF]=	48,4
resulting cable inductance	Lc [μH]=	88

safety-related values of the interconnection:

Zenerbarriere 167		Alicat IS-Max/Pro		Intrinsic safety fulfilled
26,25	Uo ≤ Ui	28	V	YES
0,084	Io ≤ Ii	0,093	A	YES
0,549	Po ≤ Pi	0,651	P	YES
48,5	Co ≥ Ci + Cc	48,4	nF / IIC	YES
2530	Lo ≥ Li + Lc	88	μH / IIC	YES

Special conditions in the type examination certificate or in the manual of the associated / intrinsically safe equipment must be observed.

The proof of intrinsic safety is based on the safety-related maximum values. These were taken from the manual or the EC type examination certificates for the equipment.

Configuration recommendation:

Please refer to the table at <https://support.microtronics.com/mydatalogeasy-iot-atex/compatible-sensors> for the configuration recommendation.



The recommendation refers to the configuration of your Jellox product. You can make the settings in the platform.

Document revision

version	date	name	change	reason
01v000	07.03.2025	AZ	all	building document

Release

number	date	name	activity	signature
1	07.03.2025	AZ	created	
2			approved	